



Standards Council of Canada
Conseil canadien des normes

INSPECTION BODY ACCREDITATION PROGRAM

Accredited Legal Entity:



ESA FIELD EVALUATION SERVICES GROUP Electrical Safety Authority

1 Terence Matthews Crescent, Suite 130, Ottawa, ON K2M 2G3 Canada
 Telephone: (613) 271-1489 Telefax: (613) 271-6441
 Email: luis.romero@electricalsafety.on.ca

Accreditation Standards:

CAN-P-8 (ISO/IEC 17020:1998)
 IAF-ILAC-A4 2004 GD17020
 CAN-P-1608

Inspection Logo:



"P" Series - Approval of electrical panels only.

"S" Series - On all other electrical equipment.

Note: The labels presented above are in accordance with CSA-SPE-1000-09 and are effective as of April 01, 2010.

Subject Area of Accreditation:

The performing of field inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:


- As identified in the scope of CSA SPE-1000-09 Model Code for the field evaluation of electrical equipment, but excluding:
- (a) wire and cable products;




- (b) wiring devices;
- (c) equipment for use in hazardous locations;
- (d) medical electrical equipment and systems;
- (e) components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- (f) equipment rated more than 46 kV; and
- (g) any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone).

*Special inspection/field evaluation only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.

Product inspected prior to April 01, 2010 was labeled in accordance with CSA-SPE-1000-99 as represented by the labels below.



"P" Series - Approval of electrical panels only.



"S" Series - On all other electrical equipment.